

PINNACLE MUSEUM TOWER ASSOCIATION

EXHIBIT E

FLOOR MODIFICATIONS ACOUSTICAL REQUIREMENTS

1. The following contractor must submit proof (laboratory test data obtained through the manufacturer) that the material selected (wood, tile, marble, etc.) in combination with the underlayment chosen and installed on a structure similar to Pinnacle Museum Tower floor/ceiling, provide a minimum Impact Insulation Class (IIC) rating of fifty-five (55). The contractor's submittal must include product(s) to be used and installation procedures.
2. All work must comply with the "Noise Insulation Standards" of the California Code of Regulations (CCR) Title 24 and the Uniform Building Code (UCB) Appendix 35.

I have read and understand this specification and agree to adhere to its requirements.

Address: _____

Signature of Owner: _____ Date: _____

Signature of Owner: _____ Date: _____

Installer/Contractor: _____ Date: _____